

Manifestacija 11.1.1													Manifestacija 11.1.2													Manifestacija 11.1.3													Manifestacija 11.1.4												
Type: Secondary side temp. (Designing): 36.7 / 28.3 °C													Type: Secondary side temp. (Designing): 36.7 / 28.3 °C													Type: Secondary side temp. (Designing): 36.7 / 28.3 °C													Type: Secondary side temp. (Designing): 36.7 / 28.3 °C												
Min. required differential pressure: 11.53 kPa													Min. required differential pressure: 11.53 kPa													Min. required differential pressure: 11.53 kPa													Min. required differential pressure: 11.53 kPa												
No.	Type	To T.S.	Room label	L	Pipe diameter	Effect. area	Pipe spec.	Observed heating method	m	Ap	Ap E	Value P (Pa)	No.	Type	To T.S.	Room label	L	Pipe diameter	Effect. area	Pipe spec.	Observed heating method	m	Ap	Ap E	Value P (Pa)	No.	Type	To T.S.	Room label	L	Pipe diameter	Effect. area	Pipe spec.	Observed heating method	m	Ap	Ap E	Value P (Pa)	No.	Type	To T.S.	Room label	L	Pipe diameter	Effect. area	Pipe spec.	Observed heating method	m	Ap	Ap E	Value P (Pa)
1	1NVC FL	19-2-1	19-2-1 (kupaonica)	83.0	16 x 2.0	8.7	100	438	94.4	7.2	0.1	1.56	1	1NVC FL	14-2-1	14-2-1 (kupaonica)	81.9	16 x 2.0	8.7	100	452	106.9	8.8	0.1	1.76	1	1NVC FL	09-2-1	09-2-1 (kupaonica)	82.0	16 x 2.0	8.7	100	452	107.0	8.9	0.1	1.76	1	1NVC FL	27-1-1	27-1-1 (kupaonica)	75.1	16 x 2.0	5.1	150	310	84.7	5.1	0.1	1.40
2	1NVC FL	19-2-1	19-2-1 (kupaonica)	171.9	16 x 2.0	8.0	100	403	88.8	2.9	0.1	1.56	2	1NVC FL	14-2-1	14-2-1 (kupaonica)	161.1	16 x 2.0	8.1	100	332	63.3	11.1	0.1	2.0	2	1NVC FL	09-2-1	09-2-1 (kupaonica)	161.1	16 x 2.0	8.1	100	332	63.3	11.1	0.1	2.0	2	1NVC FL	26-1-1	26-1-1 (kupaonica)	102.0	16 x 2.0	11.8	150	479	130.4	11.8	0.1	2.36
3	1NVC FL	18-1-1	18-1-1 (kupaonica)	165.4	16 x 2.0	10.2	100	447	84.2	6.9	0.1	1.48	3	1NVC FL	13-1-1	13-1-1 (kupaonica)	100.4	16 x 2.0	13.0	100	661	106.3	11.3	0.1	1.80	3	1NVC FL	08-1-1	08-1-1 (kupaonica)	100.4	16 x 2.0	13.0	100	662	106.4	11.3	0.1	1.80	3	1NVC FL	25-1-2	25-1-2 (kupaonica)	100.3	16 x 2.0	12.8	150	710	126.2	12.8	0.1	2.36
4	1NVC FL	18-1-2	18-1-2 (kupaonica)	86.0	16 x 2.0	11.4	150	495	76.1	5.3	0.1	1.25	4	1NVC FL	13-1-2	13-1-2 (kupaonica)	97.2	16 x 2.0	11.3	150	825	109.5	11.0	0.1	1.48	4	1NVC FL	08-1-2	08-1-2 (kupaonica)	96.3	16 x 2.0	11.3	150	830	106.4	11.0	0.1	1.48	4	1NVC FL	30-1-1	30-1-1 (kupaonica)	71.9	16 x 2.0	7.7	150	442	106.1	7.7	0.1	1.40
5	1NVC FL	18-1-3	18-1-3 (kupaonica)	61.9	16 x 2.0	18.0	150	760	73.3	4.8	0.1	1.35	5	1NVC FL	13-1-3	13-1-3 (kupaonica)	63.2	16 x 2.0	18.3	150	383	87.3	6.3	0.1	1.48	5	1NVC FL	08-1-3	08-1-3 (kupaonica)	63.3	16 x 2.0	18.3	150	391	87.3	6.3	0.1	1.48	5	1NVC FL	30-1-2	30-1-2 (kupaonica)	73.0	16 x 2.0	6.5	150	375	100.9	7.6	0.1	1.76
6	1NVC FL	18-1-4	18-1-4 (kupaonica)	82.9	16 x 2.0	7.2	150	315	71.2	4.4	0.1	1.10	6	1NVC FL	13-1-4	13-1-4 (kupaonica)	85.1	16 x 2.0	9.3	150	439	91.6	7.0	0.1	1.36	6	1NVC FL	08-1-4	08-1-4 (kupaonica)	83.4	16 x 2.0	9.3	150	439	89.2	6.6	0.1	1.40	6	1NVC FL	31-1-1	31-1-1 (kupaonica)	87.7	16 x 2.0	8.9	150	512	130.9	13.5	0.1	2.16
7	1NVC FL	18-1-5	18-1-5 (kupaonica)	85.4	16 x 2.0	8.4	150	362	74.6	5.0	0.1	1.30	7	1NVC FL	13-1-5	13-1-5 (kupaonica)	85.4	16 x 2.0	11.0	150	503	93.2	7.3	0.1	1.50	7	1NVC FL	08-1-5	08-1-5 (kupaonica)	83.4	16 x 2.0	10.8	150	495	89.2	6.5	0.1	1.44	7	1NVC FL	32-1-1	32-1-1 (kupaonica)	81.3	16 x 2.0	8.7	150	514	126.6	10.8	0.1	2.00
8	1NVC FL	18-1-6	18-1-6 (kupaonica)	36.1	16 x 2.0	5.1	150	411	70.7	5.1	0.1	2.00	8	1NVC FL	09-1-1	09-1-1 (kupaonica)	39.1	16 x 2.0	5.4	150	338	66.6	4.4	0.1	1.40	8	1NVC FL	09-1-2	09-1-2 (kupaonica)	37.2	16 x 2.0	21.1	150	1235	203.7	20.0	0.1	2.76	8	1NVC FL	33-1-1	33-1-1 (kupaonica)	39.0	16 x 2.0	7.3	150	300	76.3	3.6	0.1	1.20
9	1NVC FL	18-1-7	18-1-7 (kupaonica)	80.7	16 x 2.0	11.4	150	489	78.3	5.6	0.1	1.38	9	1NVC FL	22-1-1	22-1-1 (kupaonica)	79.9	16 x 2.0	9.3	150	341	122.5	11.0	0.1	2.00	9	1NVC FL	25-1-1	25-1-1 (kupaonica)	47.7	16 x 2.0	4.6	150	383	42.5	2.0	0.1	1.00	9	1NVC FL	34-1-1	34-1-1 (kupaonica)	86.5	16 x 2.0	9.3	150	541	126.6	13.1	0.1	2.16
10	1NVC FL	15-1-1	15-1-1 (kupaonica)	67.8	16 x 2.0	5.4	150	336	101.3	8.7	0.1	1.60	10	1NVC FL	21-1-1	21-1-1 (kupaonica)	61.7	16 x 2.0	9.3	150	542	120.0	11.6	0.1	2.00	10	1NVC FL	23-1-1	23-1-1 (kupaonica)	88.4	16 x 2.0	9.3	150	542	132.2	13.8	0.1	2.20	10	1NVC FL	35-1-1	35-1-1 (kupaonica)	97.4	16 x 2.0	5.3	150	330	94.6	6.8	0.1	1.20
11	1NVC FL	20-1-1	20-1-1 (kupaonica)	89.0	16 x 2.0	13.3	150	755	141.7	15.7	0.2	2.35	11	1NVC FL	06-1-1	06-1-1 (kupaonica)	62.1	16 x 2.0	14.9	150	760	64.8	2.8	0.1	1.00	11	1NVC FL	06-2-1	06-2-1 (kupaonica)	101.9	16 x 2.0	13.4	150	706	106.4	11.0	0.1	1.76	11	1NVC FL	06-3-1	06-3-1 (kupaonica)	101.0	16 x 2.0	14.0	150	736	109.7	12.0	0.1	1.80
12	1NVC FL	20-1-2	20-1-2 (kupaonica)	87.9	16 x 2.0	11.0	150	635	136.7	14.6	0.2	2.20	12	1NVC FL	06-1-2	06-1-2 (kupaonica)	101.9	16 x 2.0	13.4	150	706	106.4	11.0	0.1	1.76	12	1NVC FL	06-2-2	06-2-2 (kupaonica)	101.0	16 x 2.0	14.0	150	736	109.7	12.0	0.1	1.80	12	1NVC FL	06-3-2	06-3-2 (kupaonica)	101.7	16 x 2.0	14.0	150	736	109.7	12.0	0.1	1.80
13	1NVC FL	20-1-3	20-1-3 (kupaonica)	87.9	16 x 2.0	9.7	150	544	133.1	13.7	0.2	2.20	13	1NVC FL	06-1-3	06-1-3 (kupaonica)	96.3	16 x 2.0	10.3	150	530	93.9	7.7	0.1	1.50	13	1NVC FL	06-2-3	06-2-3 (kupaonica)	101.7	16 x 2.0	14.0	150	736	109.7	12.0	0.1	1.80	13	1NVC FL	06-3-3	06-3-3 (kupaonica)	101.7	16 x 2.0	14.0	150	736	109.7	12.0	0.1	1.80



Manifestacija 11.1.5													Manifestacija 11.1.6													Manifestacija 11.1.7													Manifestacija 11.1.8												
Type: Secondary side temp. (Designing): 36.7 / 28.3 °C													Type: Secondary side temp. (Designing): 36.7 / 28.3 °C													Type: Secondary side temp. (Designing): 36.7 / 28.3 °C													Type: Secondary side temp. (Designing): 36.7 / 28.3 °C												
Min. required differential pressure: 11.53 kPa													Min. required differential pressure: 11.53 kPa													Min. required differential pressure: 11.53 kPa													Min. required differential pressure: 11.53 kPa												
No.	Type	To T.S.	Room label	L	Pipe diameter	Effect. area	Pipe spec.	Observed heating method	m	Ap	Ap E	Value P (Pa)	No.	Type	To T.S.	Room label	L	Pipe diameter	Effect. area	Pipe spec.	Observed heating method	m	Ap	Ap E	Value P (Pa)	No.	Type	To T.S.	Room label	L	Pipe diameter	Effect. area	Pipe spec.	Observed heating method	m	Ap	Ap E	Value P (Pa)	No.	Type	To T.S.	Room label	L	Pipe diameter	Effect. area	Pipe spec.	Observed heating method	m	Ap	Ap E	Value P (Pa)
1	1NVC FL	39-1-1	39-1-1 (kupaonica)	87.7	16 x 2.0	4.9	150	493	68.9	3.4	0.1	1.15	1	1NVC FL	52-1-1	52-1-1 (kupaonica)	99.8	16 x 2.0	12.1	150	1004	148.0	19.1	0.1	2.40	1	1NVC FL	04-1-1	04-1-1 (kupaonica)	75.7	16 x 2.0	11.8	150	740	103.2	7.7	0.1	1.70	1	1NVC FL	04-1-1	04-1-1 (kupaonica)	55.4	16 x 2.0	6.7	150	488	73.3	3.0	0.1	1.00
2	1NVC FL	40-1-1	40-1-1 (kupaonica)	94.9	16 x 2.0	13.7	150	845	113.7	11.5	0.2	1.80	2	1NVC FL	51-1-1	51-1-1 (kupaonica)	79.9	16 x 2.0	16.1	150	973	93.0	6.3	0.1	1.50	2	1NVC FL	05-1-1	05-1-1 (kupaonica)	26.8	16 x 2.0	3.8	150	255	57.8	0.7	0.2	0.95	2	1NVC FL	04-1-1	04-1-1 (kupaonica)	61.8	16 x 2.0	30.3	150	1322	18.9	7.1	0.1	1.00
3	1NVC FL	40-2-1	40-2-1 (kupaonica)	73.5	16 x 2.0	8.1	150	506	83.5	5.2	0.1	1.30	3	1NVC FL	51-2-1	51-2-1 (kupaonica)	76.7	16 x 2.0	11.9	150	727	93.1	6.6	0.1	1.50	3	1NVC FL	05-1-2	05-1-2 (kupaonica)	61.8	16 x 2.0	30.3	150	1322	18.9	7.1	0.1	1.00	3	1NVC FL	04-1-1	04-1-1 (kupaonica)	61.8	16 x 2.0	30.3	150	1322	18.9	7.1	0.1	1.00
4	1NVC FL	40-2-2	40-2-2 (kupaonica)	71.8	16 x 2.0	6.7	150	451	78.8	4.7	0.1	1.20	4	1NVC FL	51-1-2	51-1-2 (kupaonica)	64.3	16 x 2.0	12.8	150	807	113.2	11.1	0.1	1.80	4	1NVC FL	05-1-3	05-1-3 (kupaonica)	66.0	16 x 2.0	16.5	150	812	79.4	3.6	0.1	1.20	4	1NVC FL	04-1-1	04-1-1 (kupaonica)	61.8	16 x 2.0	30.3	150	1322	18.9	7.1	0.1	1.00
5	1NVC FL	41-1-1	41-1-1 (kupaonica)	71.4	16 x 2.0	6.1	150	384	79.6	4.5	0.1	1.10	5	1NVC FL	51-2-2	51-2-2 (kupaonica)	64.1	16 x 2.0	11.3	150	753	118.6	10.8	0.1	1.80	5	1NVC FL	05-1-4	05-1-4 (kupaonica)	66.0	16 x 2.0	16.5	150	812	79.4	3.6	0.1	1.20	5	1NVC FL	04-1-1	04-1-1 (kupaonica)	61.8	16 x 2.0	30.3	150	1322	18.9	7.1	0.1	1.00
6	1NVC FL	41-1-2	41-1-2 (kupaonica)	66.6	16 x 2.0	9.2	150	510	78.4	4.3	0.1	1.35	6	1NVC FL	51-3-1	51-3-1 (kupaonica)	73.0	16 x 2.0	7.4	150	463	87.7	5.0	0.1	1.40	6	1NVC FL	05-1-5	05-1-5 (kupaonica)	68.3	16 x 2.0	10.5	150	516	72.9	3.8	0.1	1.20	6	1NVC FL	04-1-1	04-1-1 (kupaonica)	61.8	16 x 2.0	30.3	150	1322	18.9	7.1	0.1	1.00
7	1NVC FL	41-1-3	41-1-3 (kupaonica)	71.3	16 x 2.0	4.1	150	248	78.7	4.6	0.1	1.10	7	1NVC FL	51-3-2	51-3-2 (kupaonica)	68.5	16 x 2.0	14.4	150	1038	87.1	5.2	0.1	1.80	7	1NVC FL	05-1-6	05-1-6 (kupaonica)	100.0	16 x 2.0																				